### BUREAU OF PUBLIC WATER SUPPLY

## CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

List PWS ID #s for all Water Systems Covered by this CCR

| The Fe confide must be                  | deral Safe Drink<br>nce report (CCR<br>mailed to the cu                       | cing Water Act requires each <i>con</i> ) to its customers each year. Depensioners, published in a newspaper                       | nmunity public water systemoding on the population seres of local circulation, or prov   | om to develop and distribute a consumer ved by the public water system, this CCR vided to the customers upon request.                |
|---|---|--|--|--|
| Please.                                 | Answer the Follo  | owing Questions Regarding the C  | onsumer Confidence Repo  | t  |
| X                                       | Customers were  | e informed of availability of CCR 1  | oy: (Attach copy of publicat   | ion, water bill or other)  |
|   |   | Advertisement in local paper<br>On water bills<br>Other  |  |  |
|   | Date custome  | rs were informed: $\frac{5'/31/1}{}$   | 2  |  |
|   | CCR was dist  | ributed by mail or other direct  | delivery. Specify other  | direct delivery methods:   |
|   | Date Mailed/Di  | stributed: / /   |  |  |
| X                                       |   | shed in local newspaper. (Attach c   |  |  |
|   | Name of News <sub>l</sub>   | paper: <u>Southern</u>   | 9dvocate   |  |
|   |   | : 5 13/1/2   |  |  |
|   | CCR was poste   | d in public places. (Attach list of l  | ocations)  |  |
| -                                       | Date Posted: 5  | 12412  |  |  |
|   | CCR was poste   | d on a publicly accessible internet  | site at the address: www   |  |
|   | IFICATION   |  |  |  |
| I hereb<br>the for<br>consist<br>Depart | y certify that a c<br>m and manner ic<br>ent with the wa<br>ment of Health, E | onsumer confidence report (CCR) lentified above. I further certify ter quality monitoring data prov Bureau of Public Water Supply. | has been distributed to the<br>that the information includ<br>ided to the public water s | e customers of this public water system in<br>ed in this CCR is true and correct and is<br>system officials by the Mississippi State |
| Name                                    | Ulen<br>Title (President,   | Mayor, Owner, etc.)  |  | 6-18-12<br>Date  |

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215 Phone: 601-576-7518

is

#### 2012 MAY 15 PM 4: 59

2011 Annual Drinking Water Quality Report Town of Hickory Flat PWS#: 0050002 May 2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Ripley Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Hickory Flat have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Marshall Drewery at 662-333-7884. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Hickory Flat Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) — The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

|              |                  |                   |                   | TEST R  | ESULT                    | ΓS   |     |   |
|--------------|------------------|-------------------|-------------------|---|--------------------------|------|-----|---|
| Contaminant  | Violation<br>Y/N | Date<br>Collected | Level<br>Detected | Range of Detects<br>or # of Samples<br>Exceeding<br>MCL/ACL | Unit<br>Measure<br>-ment | MCLG | MCL | Likely Source of Contamination  |
| Inorganic    | : Contar         | minants           | }                 |   |                          |      |     |   |
| 10. Barium   | N                | 2011              | .017              | No Range  | ppm                      | 2    | 2   | Discharge of drilling wastes; discharge from metal refineries; erosion of natura deposits |
| 13. Chromium | N                | 2011              | 3.7               | 3.6 – 3.7   | ppb                      | 100  | 100 | Discharge from steel and pulp mills; erosion of natural deposits                          |

| 14. Copper       | N       | 2009/11 | .2   | 0        | ppm | 1.3 | AL=1.3   | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
|------------------|---------|---------|------|----------|-----|-----|----------|---|
| 16. Fluoride     | N       | 2011    | .134 | .131134  | ppm | 4   |          | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead         | N       | 2009/11 | 10   | 0        | ppb | 0   |          | Corrosion of household plumbing systems, erosion of natural deposits  |
| Volatile O       |         |         |      |          |     |     |          |   |
| 66. Ethylbenzene | : N     | 2011    | .63  | .6163    | ppb | 700 |          | Discharge from petroleum refineries   |
| 76. Xylenes      | N       | 2011    | .001 | No Range | ppm | 10  |          | Discharge from petroleum factories; discharge from chemical factories   |
| Disinfection     | on By-I | Product | S    |          |     |     |          |   |
| Chlorine         | N       | 2011    | .7   | .5 – 1.3 | ppm | 0   | MRDL = 4 | Water additive used to control microbes   |

<sup>\*</sup> Most recent sample. No sample required for 2011.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

#### \*\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were requires to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Town of Hickory Flat works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

# 2011 Annual Drinking Water Quality Report Town of Hickory Flat ECEIVED - WATER SUPPLY May 2012

We're pleased to present to you this year's Annual Quality Water Report. This report 2 Company at Quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continuelly improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Ripley Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Hickory Flat have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Marshall Drewery at 662-333-7884. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Hickory Flat Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from unban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive conteminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water posses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) — The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

|             |                  |                   |                   | TEST R  | ESUL                     | r <b>s</b> |     |                                |
|-------------|------------------|-------------------|-------------------|---|--------------------------|------------|-----|--------------------------------|
| Contaminant | Violation<br>Y/N | Date<br>Collected | Level<br>Detected | Range of Detects<br>or # of Samples<br>Exceeding<br>MCL/ACL | Unit<br>Measure<br>-ment | MCLG       | MCL | Likely Source of Contamination |

| 10. Barium                           | N     | minant<br>  2011 | .017   | No Range             | ppm        | 2         | 2         | Discharge of drilling wastes; discharge from metal refineries; erosion of natural  |
|--------------------------------------|-------|------------------|--------|----------------------|------------|-----------|-----------|--|
|                                      | 7.    |                  |        |                      |            |           |           | deposits   |
| 13. Chromium                         | N     | 2011             | 3.7    | 3.6 3.7              | bbp        | 100       | 100       | Discharge from steel and pulp mills; erosion of natural deposits   |
| 14. Copper                           | N     | 2009/11          | .2     | 0                    | ppm        | 1.3       | AL=1.3    | Corrosion of household plumbing<br>systems; erosion of natural deposits;<br>leaching from wood preservatives                       |
| 16, Fluoride                         | N     | 2011             | .134   | .131134              | ppm        | 4         | 4         | Erosion of natural deposits; water<br>additive which promotes strong teeth;<br>discharge from fertilizer and aluminum<br>factories |
| 17. Lead                             | N     | 2009/11          | 10     | 0                    | ppb        | 0         | AL=15     | Corrosion of household plumbing systems, erosion of natural deposits   |
| Volatile C                           |       | e Contai         | minant | \$ .6163<br>No Range | ppb<br>ppm | 700<br>10 | 700<br>10 | Discharge from petroleum refineries Discharge from petroleum factories;  |
| 2002                                 | , IN  | 2011             | 1.00   | 1.0.00               | 15         |           |           | discharge from chemical factories  |
| 76. Xylenes                          |       |                  |        |                      |            |           |           |  |
| <sup>78.</sup> Xylenes<br>Disinfecti | on By | Produc           | ts     | 1.5-1.3              | ppm        | l o       | MRDL =    | 4   Water additive used to control   |

<sup>\*</sup> Most recent sample. No sample required for 2011.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Holline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 801,676,7582 if you wish to have your water tested. 601.676,7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers, EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptospondium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

#### \*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were requires to sample quarterly for radionuclides beginning January 2007 — December 2007. Your public water supply completed sampling by the seduled deadline; however, during an audit of the January 2007 — December 2007. Your public water supply completed sampling by the seduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and results until further notice. Although this was not the result of inaction by the public water reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monthoring requirements. The Bureau of Public Water Supply has taken action to ansure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576,7518.

The Town of Hickory Flat works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

TOWN OF HICKORY FLAT RECEIVED WATER SUPPLY Public Places Posted 2012 JUN 25 AM 10:22

- 1 Hickory Flat Town HAll
- @ Post Office 3 BANK